

Everpure 6TS Replacement Cartridge

Applicable for commercial water purifier MRSGo-400S



Type selection

SA21079: Everpure 6TS Replacement Cartridge

Features & Benefits

- 0.5 micron1 filtration accuracy ¹
- Dirt-holding capabilities²
- Chlorine, carbon tetrachloride, volatile phenol and other organics reduction for commercial application ²
- Anti-scaling formula ¹

Installation tips

- Install vertically with cartridge hanging down.
- Allow 64mm clearance below the cartridge for easy cartridge replacement.
- Flush cartridge by running water through filter for thirty (30) minutes at full flow.

Operation tips

- Change cartridges on a regular 6-12 monthpreventative maintenance program.
- The service life is the recommended replacement cycle. The actual service life of the cartridge will vary depending on the actual water usage conditions and local tap water quality
- Change cartridges when capacity is reached or when pressure falls below 10 psi (0.7 bar).
- Always flush the filter cartridge at time of installation and cartridge change

Sizing

- Service flow rate 3: 2.5Gpm (9.5Lpm)
- Rated capacity 3: 35,000Gallons (132,489L)

¹ In accordance with the water-related product hygiene license approval for adaption system, (Jiangsu) Hygiene-Water (2023) No. 3200-0013

² In accordance with MOH Overall Performance Test Report of cartridge adaptation system MRSGo-400S, report No.: (Environmental Water) Test Report No. 20221187, (Environmental Water) Test Report No. 20221188

³ The treatment capacity refers to the overall performance of the cartridge adaptation system, and is based on Test Report SZ-LAB-2023138001 (G) from the laboratory of Pentair

Everpure 6TS Replacement Cartridge



Specifications

Service flow rate ³: 2.5GPM (9.5Lpm)

Rated capacity ³: 35,000Gallons(132,489L)

• Pressure requirements: 20 - 50 psi (1.4 – 3.5 bar)

• Temperature: 41 - 100°F (5 - 38°C)

Overall dimensions: Φ8×43.4cm

Precautions

- The Everpure integrated cartridge is mainly used for filtering and purifying municipal tap water. It shall not be used to treat water sources not fully disinfected and containing unsafe or unknown microbial loads.
- It is recommended to flush before use after a water cut-off of 48 hours.



Pentair Offices in South East Asia

Singapore 390 Havelock Road #04-01 King's Centre Singapore 169662 Tel: +6567685900

16th Floor, The Ninth Towers Grand RAMA 9, Tower B 33/4 Rama 9 Road, Huaykwang Bangkok 10310, Thailand Tel: +6621681092 Philippines 5th Floor MAIA Suites 1747 Nicanor Garcia Street corner D.Oliman Street Makati City, Philippines Tel: +632824 3825